

AFRC Technical Interpretation Request Form

Please complete the highlighted fields and return to the AFRC.

Mail: Suite 1, Level 1, Building 1, 20 Bridge Street, Pymble NSW 2073

Email: Sustainability@agwa.com.au

Interpretation Requested:

Is there any limitation to the use of NFRC TI-2016-01? Can this technical interpretation be used to calculate both Uw and SHGCw results?

<i>Date Requested:</i>	<i>Initial Interpretation Date:</i>	<i>Final TAC Approval Date:</i>
15/09/2016	15/09/2016	16/12/2016

Pertinent Document:

NFRC TI-2016-01

Referenced Sections:

Referenced Pages:

Interpretation :

NFRC TI-2016-01 shall only be used to generate Uw results. NFRC TI-2016-01 is not suitable for use in the generation of SHGCw results and shall not be used in this manner.

Technical Committee Revisions to Initial Interpretation: